



Clinton Township School District

128 Cokesbury Rd.
Lebanon, NJ 08833
(908) 236-7235

July 23, 2017

Clinton Township School District
Patrick McGaheran School
63 Allerton Road
Lebanon, NJ 08833

Dear Patrick McGaheran School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, the Clinton Township School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Patrick McGaheran School has implemented immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 $\mu\text{g/l}$ (parts per billion [ppb]). This includes turning off the outlets until re-testing or remediation shows lead concentrations are below the action level. As a precaution, all sinks across the district will have signage posted which reads, "Safe for Handwashing Only – Do Not Drink".

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we identified and tested all drinking water and food preparation outlets. Of the 77 samples taken, all but eight tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 $\mu\text{g/l}$ [ppb]).

The table below identifies the drinking water outlets that tested above the 15 $\mu\text{g/l}$ for lead, the actual lead level, and steps Clinton Township School District staff has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in $\mu\text{g/l}$ (ppb)	Remedial Action
Room B2 – Sink Faucet ID# PME-01-B-2-S-P	46.1	Disconnected outlet. Replacing faucet.
Room A7 – Sink Faucet ID# PME-01-A-7-S-P	21.7	Disconnected outlet. Replacing faucet.
Room A8 – Sink Faucet ID# PME-01-A-8-S-P	20.5	Disconnected outlet. Replacing faucet.
Room A16 – Sink Faucet ID# PME-01-A-16-S-P	55.4	Disconnected outlet. Replacing faucet.

Room A18 – Sink Faucet ID# PME-01-A-18-S-P	21.2	Disconnected outlet. Replacing faucet.
Room 31 – Sink Faucet ID# PME-01-31-S-P	17.7	Disconnected outlet. Replacing faucet.
Room 36A – Sink Faucet ID# PME-01-36A-S-P	35.4	Disconnected outlet. Replacing faucet.
Room 35B – Sink Faucet ID# PME-01-35B-S-P	27	Disconnected outlet. Replacing faucet.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning may contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 3:30 p.m., Monday through Thursday, and are also available on our website at www.ctsdnj.org. For more information about water quality in our schools, contact the School Business Administrator in the Clinton Township School District Business Office, (908) 236-7235.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Gina M. Villani

Gina M. Villani, Ed.D.
Superintendent of Schools